



ADDENDUM NO. 2  
FOR  
PIN 8761.51  
RECONSTRUCTION OF OAKWOOD DRIVE  
BID NO. 2019-010

Please be advised of the following:

**The sign-in sheet from the Pre-Bid Meeting is attached.**

**QUESTIONS RECEIVED AND CLARIFICATIONS PROVIDED AT FEBRUARY 4, 2020  
PRE-BID MEETING AND SITE WALK:**

1. Who is responsible for performing the wet taps?

**ANSWER:**

**Contractor is responsible for water main connections and valve installations. The City is allowing off-peak isolation to construct the tees without wet taps. See Section K, plans, and specifications for further requirements.**

2. What are the limitations regarding noise during construction?

**ANSWER:**

**Noise is permitted Monday through Friday, during the hours of 8:00 A.M. to 8:00 P.M. and Saturdays during the hours of 9:00 A.M. to 5:00 P.M. Noise is not permitted on Sundays or Holidays. See Chapter 391 Section 5 of the City of Peekskill Code for further requirements.**

(continued on next page)

3. What is the total federal grant amount?

**ANSWER:**

**The total federal grant amount is \$0.899M**

4. Who is the resident engineer throughout the duration of construction?

**ANSWER:**

**Tectonic will serve as the Resident Engineer for the duration of construction.**

5. Is there access to the upper section of Oakwood Drive that includes Hampton Oaks Apartments from another street separate from Oakwood Drive?

**ANSWER:**

**No, access from the Oakwood Drive construction area is the only ingress/egress to the Hampton Oaks Apartments. Oakwood Drive is discontinuous with Frost Lane and traffic generated from Hampton Oaks Apartments cannot proceed through Frost Lane. The project only includes the section of Oakwood Drive that directly intersects with North Division Street.**

**THIS ADDENDUM IS NOW PART OF THE CONTRACT DOCUMENTS. TO  
ACKNOWLEDGE RECEIPT OF THIS ADDENDUM, COMPLETE PAGE C-3 OF THE BID  
PROPOSAL AND SUBMIT WITH YOUR BIDDING DOCUMENTS.**

**END ADDENDUM NO. 2**

**CITY OF PEEKSKILL  
OAKWOOD DRIVE RECONSTRUCTION - PRE-BID MEETING  
CITY HALL – FEBRUARY 4, 2020  
ATTENDEES**

NAME	ASSOCIATION	PHONE	EMAIL
Robert Ciralli	Tectonic	845.534.5959	<a href="mailto:RCiralli@tectonicengineering.com">RCiralli@tectonicengineering.com</a>
Syed Ali	MTS Infrastructure	914.733.8746	<a href="mailto:shamza@mtsinfrastructure.com">shamza@mtsinfrastructure.com</a>
Walter Haecler	Green Meadows Enterprises, Inc.	845.943.5981	<a href="mailto:greenmeadowsenterprises@gmail.com">greenmeadowsenterprises@gmail.com</a>
Richard Spurloz	Green Meadows Enterprises, Inc.	845.943.5981	<a href="mailto:greenmeadowsenterprises@gmail.com">greenmeadowsenterprises@gmail.com</a>
Mike Pelczar	Montesano Bros.	914.235.4800	<a href="mailto:mikep@montesanobros.com">mikep@montesanobros.com</a>
Mark Lukasik	Tectonic	845.534.5959	<a href="mailto:MLukasik@tectonicengineering.com">MLukasik@tectonicengineering.com</a>
Mike Hagerty	City of Peekskill	914.734.4212	<a href="mailto:MHagerty@cityofpeekskill.com">MHagerty@cityofpeekskill.com</a>
David Rambo	City of Peekskill	914.734.4130	<a href="mailto:DRambo@cityofpeekskill.com">DRambo@cityofpeekskill.com</a>